

May 12, 2022
Patriot Beverages, LLC WWTP
MA0004936-1

Ms. Nam Nguyen
U.S. EPA, Water Enforcement
OES4-SMR
5 Post Office Square, Suite 100
Boston, MA 02109-3912

Dear Ms. Nguyen:

Please find attached the Monthly Operation and Maintenance Report for April 2022.

The final effluent phosphorous result was an average of 1.16lbs/day and a maximum of 2.41lbs. We have installed a new chemical feed pump for the phosphorous removal coagulant. We have also purchased a HACH DR3900 and have started taking daily final effluent samples to monitor the effectiveness of the phosphorous removal.

The WWTP is receiving off-site wastewater, daily, Monday through Saturday from the CPF facility in Ayer, Ma.

If you have any questions, please contact James Drapeau at (978) 339-5905 or e-mail at jdrapeau@cpf-nehf.com.

Sincerely,



James Drapeau
Patriot Beverages WWTP

Attachment: 001-A Discharge Monitoring Report for April 2022 submitted by NetDMR
001-T Discharge Monitoring Report for April 2022 submitted by NetDMR
MA DEP Monthly Operations and Maintenance Report for April 2022 submitted by NetDMR
Off-Site Wastewater received spreadsheet for April 2022 submitted by NetDMR